

Appendix 7.A

Noise: Proposed Noise Condition Limits

Table 7.A1 Daytime Noise Limits – Enoch Hill Wind Farm

Receptor	Proposed Noise Limit, dB LA90									
	3	4	5	6	7	8	9	10	11	12
R1 – Meikle Hill	35.0	35.0	35.0	35.0	35.0	35.0	37.9	40.5	40.5	40.5
R2 – Nith Lodge	35.0	35.0	35.0	35.0	35.0	35.0	37.9	40.9	40.9	40.9
R3 – Maneight	35.0	35.0	35.0	35.0	35.0	35.0	37.9	41.1	41.1	41.1
R4 - Knockburnie	45.0	45.0	44.9	44.9	44.8	44.8	44.8	44.8	44.8	44.8
R5 – Dalleagles	35.0	35.0	35.3	35.9	36.7	37.5	38.4	39.4	39.4	39.4
R6 – Dalleagles Terrace	35.0	35.0	35.3	35.9	36.7	37.5	38.4	39.4	39.4	39.4
R7 – Brockloch	45.0	45.0	44.9	44.8	44.7	44.7	44.7	44.7	44.7	44.7
R8 - Laglaff	35.0	35.0	35.0	35.0	36.1	37.5	38.9	39.7	39.7	39.7

Table 7.A2 Night-Time Noise Limits – Enoch Hill Wind Farm

Receptor	Proposed Noise Limit, dB LA90									
	3	4	5	6	7	8	9	10	11	12
R1 – Meikle Hill	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0
R2 – Nith Lodge	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0
R3 – Maneight	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0
R4 - Knockburnie	45.0	45.0	44.9	44.9	44.8	44.8	44.8	44.8	44.8	44.8
R5 – Dalleagles	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0
R6 – Dalleagles Terrace	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0
R7 – Brockloch	45.0	45.0	44.9	44.8	44.7	44.7	44.7	44.7	44.7	44.7
R8 - Laglaff	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0